



Certificate of Continued Compliance 242350106/AA/01



Issued	10-12-2025	Replaces	242350106/AA/00
Expiry date	10-12-2029	Page	1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description:	Wireless Internal Siren
Trademark:	Crow
Type designation:	CB-SIR-IN
Hardware / Software:	05 / 0.1.x.x

Placed on the market under the name or trademark of:

Name of the manufacturer:	CROW Electronic Engineering Ltd.
Address:	12 Kineret Street
City:	70100 Airport City
Country:	IL

This certificate is granted to:

Name of the certificate holder:	CROW Electronic Engineering Ltd.
Address:	12 Kineret Street
City:	70100 Airport City
Country:	IL

Wim van Loon
Managing director Nederland

Kiwa Nederland B.V.
Kiwa FSS Products
Wilmsdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

This certificate has THREE Annexes.

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



Remarks and observations

The following conditions are applicable:

Security grade: 2

Environmental class: II

Equipment class: Fixed

Warning device type: W

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.
Electromagnetic emission and safety aspects are not covered by this certificate.

The x visible in the sw version stands for a digit that can change in case of minor changes.
The certified version is recorded in the certification file together with any reported minor changes.

Factory location:

CROW Electronic Engineering Ltd

HaMasger St.2

Afula

Israel

Product inspection location:

CROW Electronic Engineering Ltd

12 Kinret Street

Airport City

Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Hermon Laboratories Ltd.: CROIAS_EN 20131-4.144397, 25 September 2025
- ANPI asbl: LAB/BIS/REC/1545- 2/25, 19 August 2024
- Hermon Laboratories Ltd.: CROEMC_EN.51967.doc, 04 December 2023
- Hermon Laboratories Ltd.: CROENV_EN.53606.1.doc, 14 August 2024
- Hermon Laboratories Ltd.: croraden51967en-50131-5-3, 12 March 2024

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-4 April, 2019

Applied Standards

EN 50130-5 June, 2011
EN 50130-4+A1 October, 2014
EN 50131-5-3 March, 2017
EN 50131-1+A1+A2+A3 June, 2020

The product as described in this certificate includes the following type designations

- Product description: Wireless Internal Siren
- Trademark: Crow
- Type designation: CB-SIR-IN
- Hardware version: 05
- Software version: 0.1.x.x